

## Group “B” Water Systems Approval

Group “B” Water System defined:

- A water system serving 3-14 connections and serving any number of people for less than 60 days per year **OR**
- A water system serving 3-14 connections and serving less than 25 people for 60 days or more per year.

Water systems using over 5000 gallons a day must apply for a Water Right Permit with the D.O.E (Department of Ecology) at (509)575-2800.

Water systems serving greater than 9 connections must be designed by a licensed Professional Engineer.

The following information must be submitted to our office to obtain approval of a Group “B” Water System that will serve 3-9 connections:

- Well log completed by well driller at the time the well is drilled
- Pump/Aquifer Test of well
- Pump Curve
- Completed Group “B” application & workbook
- Water Users Agreement
- Declaration of Covenant
- Restrictive Covenant
- Water Facilities Inventory (WFI) Form
- Bacteriological Test-water quality test
- Complete Inorganic-water quality test
- Must be managed by a Satellite Management Agency

A source site inspection is required to be performed prior to actual drilling to ensure optimum location is selected. If there is an existing well, an inspection must be performed and the well site approved before final approval will be granted.

**Group “B” water systems that will serve 10 to 14 connections must be approved by the Washington State Department of Health. Please submit Group “B” applications to the following address:**

State of Washington Department of Health  
16201 E. Indiana Ave., suite 1500  
Spokane Valley, WA 99216  
(509) 329-2100

### **2008-09 Group B System Fees for Kittitas County**

Source Site Inspection: \$200

Group B Application, Review, & Approval Fee: \$400