



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: 14-00751

OWNER'S NAME: RICK HAYES

DATE: 7/27/2015

TYPE: Mechanical and plumbir

TIME STARTED: 10:05 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-29051-0018

	1. Waste @ 7#/15 mins - Ok
	2. Gas @ 5# - Needs to be min of 15#/ 15 mins
	3. Fire caulking at WH B Vent not complete
	4. Draftstop installation Ok
	5. Verify product data for fireplace venting prior to enclosing
	6. Complete furnace repair - Correction 7
	7. Plumbing rough in Ok
	8. Exhaust Ok

INSTRUCTIONS: Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506