INSPECTION REPORT

OWNER'S NAME:

HOFF

BP-10-00515

PERMIT NUMBER:

DATE:		6/25/2015	TYPE:	Final	
TIME STARTED:		1:30 PM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		18-19-07000-0014			
Г					
	1. Bedroom Windows Not Egress.				
	2. (6/26/2015: Bedroom Windows are Existing. Confirmed with Building Official that scope o				
	f work does Not Require Compliance of Existing Structure.)				
INSTRUCTIONS: Verify Scope of Remodel. Install Egress Windows in all Bedrooms. (Final OK.)					
NEXT INSPECTION: Re Inspect.					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jeremy.haberman @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •					
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506					