



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-10-00801

OWNER'S NAME: VAN DORN

DATE: 2/4/2016

TYPE: Final

TIME STARTED: 4:17 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-18-08050-0014

1. Flue Ok
2. Roof penetration Ok
3. Pressure relief valve Ok
4. Gas Ok
5. Final Ok

INSTRUCTIONS: Final Ok

NEXT INSPECTION: N/A

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506