



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-11-00120

OWNER'S NAME: HINES

DATE: 8/14/2014

TYPE: Insulation

TIME STARTED: 11:17

INSPECTOR: Lou Whitford

MAP NUMBER: 17-17-15010-0010

	1. OK- MECHANICAL
	2. OK- FRAMING
	3. OK- ROUGH-IN PLUMBING - DWV-7#S 20 MIN / H2O 75#S -20 MINUTES
	4. CORRECTION - EGRESS WINDOW MEASUREMENTS TO BE MET BY FINAL

INSTRUCTIONS: VERIFY EGRESS WINDOW IN BEDROOM BY FINAL. THE STUDY DOES NOT REQUIRE EGRESS WINDOW.

NEXT INSPECTION: FINAL

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506