



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-11-00411

OWNER'S NAME: THOMPSON

DATE: 7/8/2015

TYPE: Final

TIME STARTED: 9:57 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-35000-0008

	1. hand rails in stairwell must return to the wall at both ends. Safety issue

INSTRUCTIONS: complete above. If permit expires, there will be a 65.00 fee for re-inspection

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506