



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-12-00620 OWNER'S NAME: THOMAN
DATE: 3/13/2015 TYPE: Final
TIME STARTED: 3:20 PM INSPECTOR: Jessica Contratto
MAP NUMBER: 21-14-09063-0003

	1. approved plans not on site
	2. sewer not finalized by health dept
	3. CO detector needed outside of sleeping areas
	4. seismic strapping on tanks in basement not to code
	5. fireplace manual needed to verify clearances
	6. flex duct under master bedroom is full of water
	7. unable to verify fire separation, energy and whole house venting requirements per plans
	8. compliant hand rail?

INSTRUCTIONS: have approved plans and permit card on site, complete above, call for re-inspection

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506