



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00012

OWNER'S NAME: FREED LLC

DATE: 7/1/2014

TYPE: Insulation

TIME STARTED: 1:42 PM

INSPECTOR:

	1. Fire caulk around through penetrations in draftstop at fireplace.
	2. Vapor barrier or PVA primer at insulation in garage.
	3. Re-check and seal penetrations in top and bottom plates.

INSTRUCTIONS: Complete above, then OK TO COVER.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL

ADDRESS: _____ @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506