



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00012 OWNER'S NAME: FREED LLC
DATE: 1/16/2015 TYPE: Final
TIME STARTED: 2:50 PM INSPECTOR: Lou Whitford
MAP NUMBER: 20-15-19051-0057

| | |
|--|---|
| | 1. Install cap on range exhaust at the exterior |
| | 2. Trim and provide screens in the water heater and furnace exhaust at the exterior |
| | 3. Seal fire penetrations in the garage/behind furnace |
| | 4. Install return air grille upstairs |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS:

NEXT INSPECTION: Reinspection Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506