INSPECTION REPORT

BP-13-00135

PERMIT NUMBER:

OWNER'S NAME: LEWIS

DATE:	9/2/2014	TYPE:	Shearwalls	
TIME STARTED:	11:23 AM	INSPECTOR:	Jessica Contratto	
MAP NUMBER:	19-15-06030-0014			
1. front V	W3 shear panel on right co	rner not in. S	ee nailing at next inspection	
INSTRUCTIONS: complete above				
NEXT INSPECTION:	re-shear/framing			
RE-INSPECTION FEI	E DUE? NO YES	5	\$	
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
jessica.contratto @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				
4	TIT W. Mady Street, Suite 2, Enchassing, WA 30320 V Wall Office Line, 303-302-7300			