INSPECTION REPORT

PERMIT NUMBER:	BP-13-00199	OWNER'S NAME:	PAUL NW INVESTMENTS
DATE:	8/6/2014	TYPE:	Shearwalls
TIME STARTED:		INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-19051-0072		
1. exterio	r shear ok		
2. tighten up nailing at upstairs interior P1-6 in stairwell			
	<u> </u>		
INSTRUCTIONS: ok to cover			
NEXT INSPECTION: frame/plumb/mech			
RE-INSPECTION FEE	OUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jessica.contratto @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 			