



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00199 OWNER'S NAME: PAUL NW INVESTMENTS
DATE: 9/15/2014 TYPE: Multiple (see notes)
TIME STARTED: 2:07 PM INSPECTOR: Amber Green
MAP NUMBER: 20-15-19051-0072

	1. Gaps around penetrations at firewall in attic area must be sealed with fire rated caulk
	ing.
	2. Fireplace has been covered without inspection. Manual still not provided.

INSTRUCTIONS: Complete fire caulking at firewall. Remove drywall at fireplace for inspection. Re-Fee, Re-Call.

NEXT INSPECTION: Firewall/Fireplace

RE-INSPECTION FEE DUE? ☐ NO ☒ YES \$ 65.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506