



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00272

OWNER'S NAME: JUMP

DATE: 11/19/2015

TYPE: Rough-in plumbing

TIME STARTED: 4:42 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-05040-0020

	1. Plumbing Rough In OK.
	2. Supply at 90#/15min DWV at 5#/15min.

INSTRUCTIONS: Complete Mechanical

NEXT INSPECTION: Mechanical/Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506