



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00352

OWNER'S NAME: BAILEY

DATE: 9/29/2016

TYPE: Insulation

TIME STARTED: 4:14 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-18000-0027

1. Framing OK.
2. Insulation OK.
3. NOTE: Prior Report Refers to Letter from Owner Required Stating Plumbing will Not be Used. Letter Not Provided at Time of ReInspection. Plumbing Will Need to Be Removed In Addition to the LEtter.
4. Fireplace Rough In OK.
5. NOTE: Manual For Fireplace and Venting Will Be Required at Next Inspection.

INSTRUCTIONS: DO NOT COVER PRIOR TO RESOLUTION OF PLUMBING

NEXT INSPECTION: RE INSPECT

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506