



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00500

OWNER'S NAME: BERGREN

DATE: 10/6/2015

TYPE: Multiple (see notes)

TIME STARTED: 11:54 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-35054-0003

	1. NOTE: GATE CODE IS "1314"
	2. Shearnailing OK.
	3. (2) Holdown Straps Missing at Bedroom #3. See Bubbled Area on Page 2 of 8.
	4. Mechanical OK.
	5. Gas Line @ 20#/15min. OK.
	6. Plumbing Rough In OK.
	7. Supply at 80#/15min. OK
	8. DWV at 5#/15min. OK.

INSTRUCTIONS: OK to Cover Exterior. Customer will install HDU's Interior. Verify at Framing.

NEXT INSPECTION: Framing.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506