



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00674

OWNER'S NAME: BACK COUNTRY

DATE: 7/28/2014

TYPE: Insulation

TIME STARTED:

INSPECTOR: Amber Green

MAP NUMBER: 19-15-07060-0009

	1. Per the 2012 WSEC worksheet, a minimum of R-49 insulation required in the lid.

**INSTRUCTIONS:** Complete above or provide component performance worksheet for the structure.

**NEXT INSPECTION:**

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [amber.green@co.kittitas.wa.us](mailto:amber.green@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506