## **INSPECTION REPORT**

PERMIT NUMBER:	BP-13-00707	OWNER'S NAME:	WALLACE
DATE:	11/4/2014	TYPE:	Radiant heat
TIME STARTED:	11:07 AM	INSPECTOR:	Lou Whitford
MAP NUMBER:	20-14-13050-0032		
1. OK - T	WO GAUGES @ 100#	S FOR HYDRO	NICS
2. OK FRAMING/INSULATION ONLY GARAGE INTERIOR FRONT			
3. OK TO COVER GARAGE FRONT ONLY			
INSTRUCTIONS:			
NEXT INSPECTION: FRAMING, MECHANICAL, PLUMBING			
RE-INSPECTION FEE	DUE? NO Y	ES	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
lou.whitford @co.kittitas.wa.us			
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> </ul>			

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506