



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00709

OWNER'S NAME: COLLIER

DATE: 9/22/2014

TYPE: Slab plumbing

TIME STARTED: 12:54 PM

INSPECTOR: Amber Green

MAP NUMBER: 17-18-09051-0001

| | |
|--|--|
| | 1. Plumbing needs to be on test for inspection. Either 10 stack full of water of 5 lbs o |
| | f air. |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: Place plumbing on test, re-call for inspection.

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506