



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00709 OWNER'S NAME: COLLIER
DATE: 9/24/2014 TYPE: Re-inspection
TIME STARTED: 10:29 AM INSPECTOR: Jessica Contratto
MAP NUMBER: 17-18-09051-0001

	1. slab insulation extends 2 ft down stemwalls-ok
	2. Thickened pads need 3 bars each way per plan. Add one to each
	3. DWV on stack test- ok

INSTRUCTIONS: add bars to pads, then ok to pour

NEXT INSPECTION: shearwalls

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506