



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00709 OWNER'S NAME: COLLIER
DATE: 12/2/2014 TYPE: Plumbing
TIME STARTED: 1:49 PM INSPECTOR: Jessica Contratto
MAP NUMBER: 17-18-09051-0001

| | |
|--|---------------------|
| | 1. Trusses ok |
| | 2. DWV at 7#/15-ok |
| | 3. H2O at 68#/15-ok |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: trusses and rough in plumbing ok. Complete venting and electrical for rest of framing inspection

NEXT INSPECTION: frame/mechanical

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506