



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00709

OWNER'S NAME: COLLIER

DATE: 4/29/2015

TYPE: Mechanical

TIME STARTED: 11:53 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-09051-0001

	1. Mechanical OK.
	2. Verify Exhaust Duct is Insulated at Insulation Inspection.
	3. Verify Insulation is used as fireblock in Stairwell at Insulation Inspection.

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506