



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00736

OWNER'S NAME: GOKEY

DATE: 7/10/2015

TYPE: Rough-in plumbing

TIME STARTED: 12:46 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 16-19-11000-0001

| | |
|--|------------------------------|
| | 1. Corrections Ok |
| | 2. Waste @ 5#/15 mins - Ok |
| | 3. Supply @ 86#/15 mins - Ok |
| | 4. Plumbing rough-in Ok |
| | 5. Ok to cover exterior |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: Ok to cover exterior/send pictures of CS14 straps

NEXT INSPECTION: Mechanical/Interior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506