



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00756 OWNER'S NAME: ANDERSON
DATE: 8/1/2014 TYPE: Final
TIME STARTED: INSPECTOR: Amber Green
MAP NUMBER: 20-14-24050-0323

	1. Bollard at water heater in garage.
	2. Insulate water lines at water heater in garage.

INSTRUCTIONS: Forward blower door test results to KCCDS. Complete above, then FINAL OK.

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506