



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00767 OWNER'S NAME: BUTLER
DATE: 9/23/2014 TYPE: Framing
TIME STARTED: 10:24 AM INSPECTOR: Amber Green
MAP NUMBER: 17-18-04055-0002

	1. Nails into pressure treated wood to be hot dipped galvanized.
	2. Framing OK

INSTRUCTIONS: Complete Above, then OK to Cover.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506