



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811  
DATE: 9/5/2014  
TIME STARTED: 4:03 PM  
MAP NUMBER: 17-18-08000-0016

OWNER'S NAME: MOON  
TYPE: Rough-in plumbing  
INSPECTOR: Amber Green

	1. DWV (stack/15min) - OK
	2. Complete re-bar at point load pads and thickened footings per plan.
	3. Slab Insulation - OK

INSTRUCTIONS: OK TO POUR.

NEXT INSPECTION: FRAME/PLUMB/MECH

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506