



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811 OWNER'S NAME: MOON  
DATE: 4/14/2015 TYPE: Frame-Plumb-Mech  
TIME STARTED: 10:41 AM INSPECTOR: Jeremy Haberman  
MAP NUMBER: 17-18-08000-0016

	1. Gas Line OK. 15#/15min.
	2. Supply OK. LIVE.
	3. DWV Not Complete.
	4. Range Vent Not Complete
	5. Drywall Under Stair Landing Required for Final.
	6. Fireblocking Needed at all Stairwells.
	7. Interior GluLam to Post connection Not Per Plan. See Page 5 of 6.
	8. Lower Eave Detail Not Per Plan. LVL Missing. See Framing Plan on 3 of 6.
	9. 1st Floor Kitchen Window Header Does Not Have Trimmers. Header Dimension Not Specified.
	10. Fire Separation Required at all posts and beams for Final.
	11. Fire Separation needs to Extend to Roof Deck and or Exterior.
	12. All Header Dimensions Need Specification.
	13. Truss Bracing Not Complete.

INSTRUCTIONS: DO NOT INSULATE. DO NOT COVER.

NEXT INSPECTION: Re Inspect.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811

OWNER'S NAME: MOON

DATE: 4/14/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 10:41 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08000-0016

	Page 2
	14. Balcony Deck Not PT. GluLam Out Lookers Not PT.

INSTRUCTIONS: DO NOT INSULATE. DO NOT COVER.

NEXT INSPECTION: Re Inspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506