



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811 OWNER'S NAME: MOON  
DATE: 4/16/2015 TYPE: Framing and plumbing  
TIME STARTED: 11:30 AM INSPECTOR: Jeremy Haberman  
MAP NUMBER: 17-18-08000-0016

	1. DWV OK. On Stack Test.
	2. Verify Vent Terminations at Final.
	3. Range Vent OK. Strap and Insulate Prior to Insulation Inspection.
	4. Stair Fireblocking OK.
	5. Truss Bracing OK.
	6. Interior GluLam Post to Beam Connection Not PEr Plan. See Page 5 of 6.
	7. Lower Eave Detail Not Per Plan. LVL Missing. See Framing Plan 3 of 6.
	8. 1st Floor Kitchen Window Missing Trimmers. Header Not Specified.
	9. All Header Dimensions Need Specification.
	10. Fire Seperation Required at all Post and Beam Connections.
	11. Fire Seperation Needs to Extend to Roof Deck or Exterior.
	12. All Header Dimensions Need Specification.
	13. Verify Venting of Attic Truss

INSTRUCTIONS: OK to Insulate. Ensure Corrections are Visible. Remaining Corrections to be addressed Prior to Cover.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811

OWNER'S NAME: MOON

DATE: 4/16/2015

TYPE: Framing and plumbing

TIME STARTED: 11:30 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-08000-0016

	Page 2

**INSTRUCTIONS:** OK to Insulate. Ensure Corrections are Visible. Remaining Corrections to be addressed Prior to Cover.

**NEXT INSPECTION:** Insulation.

**RE-INSPECTION FEE DUE?**



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506