



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00811 OWNER'S NAME: MOON
DATE: 4/24/2015 TYPE: Insulation
TIME STARTED: 10:07 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 17-18-08000-0016

	1. Overhead Attic Insulation OK.
	2. Wall Insulation OK.
	3. CCQ-58 Post Cap Correction OK.
	4. Header Clarification Still Needed. Drawings Do Not Specify Header Dimensions. Lower Kitchen Window Trimmers are Not Acceptable.
	5. LVL Alternate Clarification Still Needed.
	6. Verify at Final All Beams and Post Must Be Drywall Wrap.
	7. Adequate Ventilation Required Attic Spaces.
	8. Verify Exterior Plumbing Vents at Final.

INSTRUCTIONS: DO NOT COVER.

NEXT INSPECTION: Re-Inspect.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506