



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-13-00811

OWNER'S NAME: MOON

DATE: 7/10/2015

TYPE: Final

TIME STARTED: 2:09 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-18-08000-0016

	1. Exterior weather tight membrane not complete
	2. Garage electrical not covered in multiple locations
	3. Fire separation not sealed in garage
	4. Drawings not found on site

INSTRUCTIONS: Final inspection not performed/Re-Inspection when complete

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506