



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00817 OWNER'S NAME: MORGAN
DATE: 10/27/2014 TYPE: Exterior shear
TIME STARTED: 2:29 PM INSPECTOR: Amber Green
MAP NUMBER: 21-14-34050-0001

	1. Tighten up nailing at P1-4 walls to 4" oc at all panel edges.
	2. Complete strapping per H/S1 at all windows on first floor per engineering.

INSTRUCTIONS: Complete #1, Complete #2 and provide pictures to the email below. Once pictures are received, OK to Tyvek.

NEXT INSPECTION: Frame/Plumb/Mech

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506