



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-13-00817 OWNER'S NAME: MORGAN
DATE: 1/26/2015 TYPE: Framing
TIME STARTED: 1:19 PM INSPECTOR: Jessica Contratto
MAP NUMBER: 21-14-34050-0001

	1. upstairs framing ok
	2. one window upstairs needs to meet egress. Maximum height from floor is 44"
	3. insulation downstairs ok
	4. add foam board filler in header spaces

INSTRUCTIONS: ok to cover downstairs

NEXT INSPECTION: final downstairs/upstairs insulation

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506