



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00040
DATE: 8/12/2014
TIME STARTED:
MAP NUMBER: 17-19-02071-0003

OWNER'S NAME: VARNUM
TYPE: Shearwalls
INSPECTOR: Jessica Contratto

	1. check and re nail all shearwalls on exterior and interior

INSTRUCTIONS: complete above. do not cover. call for re-inspection

NEXT INSPECTION: re-inspect shear

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506