

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00040	OWNER'S NAME:	VARNUM
DATE:	10/1/2014	TYPE:	Insulation
TIME STARTED:	12:56 PM	INSPECTOR:	Amber Green
MAP NUMBER:	17-19-02071-0003		

1. Please have plans on site for all inspections. To include all paperwork.			
2. Will verify hot water heater at final for compliance with the WSEC.			
3. Will check dryer vent at final.			
4. No vapor barrier installed, use PVA primer.			
INSTRUCTIONS: Ok to cover insulation.			

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?

YES

NO NO

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506