



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00060 OWNER'S NAME: WHITEHAIR
DATE: 2/12/2015 TYPE: Final
TIME STARTED: 12:30 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-29051-0099

	1. Smoke Detector In Upstairs Bonu Room Required.
	2. Seal Mechanical Penetrations on Ext. at Heat Pump
	3. Sewer Letter Needed Onsite or Emailed.
	4. Fire Sprinkler Final Required.
	5. Stairway Handrail Not Installed
	6. Fireplace Damper Literature Needed Onsite

INSTRUCTIONS: Complete Corrections. Recall Final.

NEXT INSPECTION: Re-Inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506