



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00068

OWNER'S NAME: BACK COUNTRY

DATE: 11/14/2014

TYPE: Final

TIME STARTED: 10:04 AM

INSPECTOR: Amber Green

MAP NUMBER: 19-15-07060-0003

1. Provide protection of regulator at exterior of garage wall.
2. Mud or fire caulk at drywall to top plate seams.
3. All penetrations in top plate must be fire rated caulking.
4. Insulate water lines in garage at H2O tank.
5. Post WSEC compliance certificate within 3 of electrical panel.
6. Complete electrical plate covers at kitchen.
7. Weather strip the crawl access door.

INSTRUCTIONS: Complete above, Re-call inspection.

NEXT INSPECTION: Re-Final

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506