



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00078

OWNER'S NAME: GORDON

DATE: 4/3/2017

TYPE: Re-inspection

TIME STARTED: 10:44 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12063-0007

1. Engineering for headers @ gable Ok
2. Trusses Ok
3. Garage bathroom not complete
4. Gas @ 0#
5. Attic access to be verified @ Final (3 locations per contractor)
6. Submit revisions for Game Room or define intent
7. Ductless heat pump in garage not allowed
8. DO NOT INSULATE

INSTRUCTIONS: Complete garage plumbing/Provide revision/clarification for garage attic/Pressurize gas/Verify fireplace rough in/DO NOT INSULATE

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506