



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00078

OWNER'S NAME: GORDON

DATE: 5/4/2017

TYPE: Re-inspection

TIME STARTED: 12:06 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-12063-0007

1. Fireplace RI Ok
2. Gas @ 5# - Needs to be 15#
3. No access to garage for Plumbing on test
4. Garage Access from stair not installed
5. NOTE: Revised Inspection Report from 4/10/17 left on site

INSTRUCTIONS: Insulate @ own risk until gas is inspected

NEXT INSPECTION: Gas Piping

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506