



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00083

OWNER'S NAME: DAVIDSON

DATE: 7/31/2014

TYPE: Slab plumbing

TIME STARTED:

INSPECTOR: Amber Green

MAP NUMBER: 19-17-01000-0005

| | |
|--|-----------------------|
| | DWV : (5#/15min) - OK |
| | Slab Insulation - OK |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: OK TO POUR

NEXT INSPECTION: FRAME/PLUMB/MECH

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506