INSPECTION REPORT

PERMIT NUMBER: BP-14-00088 OWNER'S NAME: NEW SUNCADIA LLC

DATE:		7/9/2014		TYPE:	Framing and plumbing
TIME STARTED:		2:35 PM		INSPECTOR:	
	Add wedge bearing block at rafters to top plate.				
	DWV (H	2O/15min)			
	Water lir	nes (working pre	essure)		
INSTRUCTIONS: OK to Insulate					
NEXT INSPECTION: Insulation					
RE-INSPECTION FEE DUE? NO YES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:@co.kittitas.wa.us					
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506					