



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00109 OWNER'S NAME: VENERA  
DATE: 11/13/2014 TYPE: Frame-Plumb-Mech  
TIME STARTED: 4:11 PM INSPECTOR: Lou Whitford  
MAP NUMBER: 17-19-29052-0002

	1. OK - H2O 80#S FOR 20 MINUTES
	2. OK - DWV - 7#S FOR 20 MINUTES
	3. OK - TRUSSES
	4. OK - FRAMING
	5. CORRECTION- SAFETY GLAZING (2) LOCATIONS LVG RM
	6. CORRECTION - SMOKE DETECTORS OUTSIDE EACH BDRM
	7. OK TO INSULATE...CHECK CORRECTIONS AT INSULATION

### INSTRUCTIONS:

NEXT INSPECTION: CORRECTIONS AND INSULATION

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_  
lou.whitford@co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506