



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00135

OWNER'S NAME: GRANITE CREEK

DATE: 1/16/2015

TYPE: Rough-in plumbing

TIME STARTED: 9:30 AM

INSPECTOR: Lou Whitford

MAP NUMBER: 19-14-03000-0086

	1. DWV on Stack - OK
	2. Plumbing at 60#/15 min - ok

INSTRUCTIONS:

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506