



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00159

OWNER'S NAME: Greenwood

DATE: 8/25/2015

TYPE: PLUMB/HEAT

TIME STARTED: 3:30 pm

INSPECTOR: HABERMAN

CORRECTION ON SHEATING OK.
GAS OK 25#/15 min.
MECHANICAL OK
VERIFY FURNACE NOT GAS
DWV ON STACK TEST
SUPPLY 55#/15 min.
P-UMBING OK
OK TO SOFFIT PORCHES. CLIPS OFF.

INSTRUCTIONS: OK TO CALL FOR FRAMING

NEXT INSPECTION: FRAMING

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506