



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00166

OWNER'S NAME: THE PASS LLC

DATE: 10/28/2014

TYPE: Rough-in plumbing

TIME STARTED: 11:49 AM

INSPECTOR: Amber Green

MAP NUMBER: 22-11-04055-0026

	1. DWV (H2O/15min) - OK H2O (working pressure) - OK
	2. Add web filler at any compromised floor joists.

INSTRUCTIONS: Will see above at framing inspection.

NEXT INSPECTION: Rough Mechanical/Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506