

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-14-00166	OWNER'S NAME:	THE PASS LLC
DATE:	11/25/2014	TYPE:	Re-inspection
TIME STARTED:	1:47 PM	INSPECTOR:	Amber Green
MAP NUMBER:	22-11-04055-0026		

	1. Corrections OK.		
	2. Add draftstop at lower floor at rear.		
INSTRUCTIONS: Re-check draftstop penetrations, fire caulk. OK to Cover			

NEXT INSPECTION: Firewall drywall nailing

RE-INSPECTION FEE DUE?

NO NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506