INSPECTION REPORT

PERMIT NUMBER:	BP-14-00175	OWNER'S NAME:	THE PASS LLC
DATE:	8/21/2014	TYPE:	Slab insulation
TIME STARTED:	1:57 PM	INSPECTOR:	Amber Green
MAP NUMBER:	22-11-04055-0034		
1. Hydror	nics (100#/15min) - OK		
2. Slab Ir	sulation OK		
INSTRUCTIONS: OK TO COVER			
NEXT INSPECTION:	Ext Shear		
RE-INSPECTION FEE	DUE? NO YES		\$
	UIRED, RE-INSPECTION FEES MUST BE		
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: amber.green @co.kittitas.wa.us			
■ INSDFC			
■ INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ● 411 N. Ruby Street, Suite 2. Ellensburg, WA 98926 ● Main Office Line: 509-962-7506			