



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00183 OWNER'S NAME: BURNSTEAD
DATE: 9/17/2014 TYPE: Exterior shear
TIME STARTED: 12:27 PM INSPECTOR: Amber Green
MAP NUMBER: 20-15-20059-0029

	1. Tighten up nailing at P1-2 shearwalls.

INSTRUCTIONS: Complete Above, then OK TO COVER.

NEXT INSPECTION: FRAME/PLUMB/MECH

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506