INSPECTION REPORT

| PERIVITI NUIVIBER: | | BP-14-00244 | OWNER'S NAIVIE: | JACOBSEN | |
|--|--|---|-----------------|----------------|--|
| DATE: | | 8/20/2014 | TYPE: | Exterior shear | |
| TIME STARTED: | | 12:31 PM | INSPECTOR: | Amber Green | |
| MAP NUMBER: | | 20-14-02061-0001 | | | |
| | 1. Compl | . Complete panel at front of structure. | | | |
| | 2. The bonus room above the existing garage was never permitted as habitable space, if the | | | | |
| | intention is to finish this space, additional permitting will be required. | | | | |
| | 3. Provide approval and change of plans for added dormir from engineer prior to framing in | | | | |
| | spection. | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| INSTRUCTIONS: Ok to cover exterior. | | | | | |
| | | | | | |
| NEXT INSPECTION: | | | | | |
| RE-INSPECTION FEE DUE? VES \$ | | | | | |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION | | | | | |
| QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: | | | | | |
| | amber.green @co.kittitas.wa.us | | | | |
| INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 | | | | | |