



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00252 OWNER'S NAME: BERRY
DATE: 10/2/2014 TYPE: Exterior shear
TIME STARTED: 2:54 PM INSPECTOR: Amber Green
MAP NUMBER: 20-15-18010-0026

	1. Complete blocking between trusses at interior P1-4 shearwall.
	2. Ok to sheath double sided shearwalls.

INSTRUCTIONS: Ok to Cover Exterior.

NEXT INSPECTION: Framing/Plumbing/Mechanical

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506