



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00259 OWNER'S NAME: PDQ CONSTRUCTION  
DATE: 10/27/2014 TYPE: Final  
TIME STARTED: 1:39 PM INSPECTOR: Amber Green  
MAP NUMBER: 20-14-12067-0006

	1. WSEC Compliance Certificate needs to be posted at the electrical panel.
	2. Fire door at garage is required to be self closing.
	3. LP Tank needs to be set on level surface.
	4. Door at rear porch not functioning.
	5. Exhaust fan in downstairs bathroom appears to not be functioning.
	6. Road Certification/Approval from Public Works.
	7. Final water/septic hook-up/approval.
	8. Final grading not complete.

INSTRUCTIONS: Complete Above. Call for Re-Inspection.

NEXT INSPECTION: Re-Final

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506