



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00292

OWNER'S NAME: O&#39;HEARN

DATE: 9/29/2015

TYPE: Final

TIME STARTED: 11:24 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-16-07030-0016

	1. Woodstove must be elevated 18" from floor for protection from combustible fumes
	2. vapor barrier needed in crawlspace area
	3. WUIC final from fire marshal required
	4. fresh air to woodstove ok
	5. deck addition framing and guards ok
	6. permit card not on site

INSTRUCTIONS: complete above, call for WUIC final and re-inspect

NEXT INSPECTION: WUIC, re-final

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506